

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50558920

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-Dingjia-CN22G00K 001

Ausstellungsdatum
18.10.2022

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*

DELIXI ELECTRIC (WUHU) LTD
Wuhu Machinery Industrial Park,
Wuhu city
241100 Anhui
P.R. China

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111259412

Geprüft nach *Tested acc. to*
EN 60898-1:2019

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Circuit Breaker (Miniature Circuit-breaker)

Type Designation : 1) CDB6i-80
Number of Poles : 1P/1P+N/2P/3P/3P+N/4P
Rated Operation Voltage (Ue) : 230/400VAC (1P) OR
240/415VAC (1P);
230VAC (1P+N) OR
240VAC (1P+N);
400V OR 415V (2P, 3P, 3P+N, 4P)
Rated Frequency : 50/60Hz
Rated Current (In) : 80A
Instantaneous Tripping Current : B/C/D-Type
Rated Short-circuit Capacity
(Icn) : 6kA
Rated Service Short-circuit
Capacity (Ics) : 6kA
Rated Insulation Voltage (Ui) : 500V
Impulse Withstand Voltage (Uimp) : 4,0kV
Degree of Protection : IP20
Suitability of Isolation : Yes
Pollution Degree : 2

8

8

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Zertifizierungsstelle



Wencai Zhang