

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection

Name and address of the applicant

DELIXI ELECTRIC LTD
Delixi High-Tech Industrial Park, Liushi Town, 325604 Yueqing City
Zhejiang, China

Name and address of the manufacturer

DELIXI ELECTRIC LTD
Delixi High-Tech Industrial Park, Liushi Town, 325604 Yueqing City
Zhejiang, China

Name and address of the factory

DELIXI ELECTRIC (WUHU) LTD
Wuhu Machinery Industrial Park, 241100 Wuhu City Anhui, China*When more than one factory*☐ Additional information on page 2

Ratings and principal characteristics

Product data

Rating: 1P, 1P+N, 2P, 3P, 3P+N, 4P
Ue: 230 / 400 Vac for 1P, 230 Vac for 1P+N, 400 Vac for 2P, 3P, 3P+N,
4P, 50 / 60 Hz
In: 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63 A
B, C and D type
Ics = 7,5 kA, Icn = Icn1 = 10 kA for CDB9H,
Ics = Icn = Icn1 = 6 kA for CDB9N
The grid distance "a": 35 mm
Reference ambient air temperature: 30 °C or 55 °C

Trademark / Brand (if any)

DELIXI ELECTRIC

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CDB9H and CDB9N

Additional information

☒ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015 and IEC 60898-1:2015/AMD1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

3334076.50, 3328014.50, 3317632.50, 3317630.50, 3315402.50,
3315402.51, 3310158.50, 3307909.50, 3307909.51, 3304921.50,
3303848.50, 3303848.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-06-27

Signature: May Liu

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional information

This certificate replaces CB NL-89869 issued on 2023-08-17 and NL-67861 issued on 2020-09-17.

Energy limiting class 3 for 1P, 2P, 3P, 4P and class 1 for 1P+N, 3P+N of B and C type according to EN 60898-1: 2019+A1:2024+A11:2024.

The upper value of instantaneous tripping of D-type is $14I_n$.

The tests were performed in 2012, 2015, 2019, 2020, 2023 and 2025.

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Date: 2025-06-27

Signature: May Liu