

ATTESTATION OF CONFORMITY

Issued to: DELIXI ELECTRIC LTD
Delixi High-Tech Industrial Park, Liushi Town 325604 Yueqing City Zhejiang, China

For the product: Circuit-breakers for overcurrent protection

Trade name: DELIXI ELECTRIC

Type/Model: CDB9H and CDB9N

Ratings: 1P, 1P+N, 2P, 3P, 3P+N, 4P, 50 / 60 Hz, Ue: 230 / 400 Vac for 1P, 230 Vac for 1P+N, 400 Vac for 2P, 3P, 3P+N, 4P, In: 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63 A, B, C and D type, Ics = 7,5 kA, Icn = Icn1 = 10 kA for CDB9H, Ics = Icn = Icn1 = 6 kA for CDB9N, Reference ambient air temperature: 30 °C or 55 °C
Energy limiting class 3 for 1P, 2P, 3P, 4P and class 1 for 1P+N, 3P+N of B and C type, the grid distance "a": 35 mm

Manufactured by: DELIXI ELECTRIC LTD
Delixi High-Tech Industrial Park, Liushi Town 325604 Yueqing City Zhejiang, China

Subject: Complete evaluation of electrical system of the appliances

Requirements: EN 60898-1:2019, EN 60898-1:2019/A1:2024, EN 60898-1:2019/A11:2024
IEC 60898-1:2015, IEC 60898-1:2015/AMD1:2019

Remark: This attestation replaces AOC no. 3328014.01-AOC issued on 2023-08-22 and 3317632.01A issued on 2020-09-27.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test reports no 3334076.50 issued on 2025-06-26, 3328014.50 issued on 2023-08-16, 3317632.50 and 3317630.50 issued on 2020-09-14, 3315402.50 issued on 2019-04-23, 3315402.51 issued on 2019-04-25, 3310158.50 issued on 2016-06-27, 3307909.50 and 3307909.51 issued on 2015-06-29, 3304921.50 issued on 2013-04-18, 3303848.50 and 3303848.51 issued on 2012-10-10.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This document does not authorize the use of any DEKRA approved mark.
Wenzhou, Zhejiang, 01 July 2025 Number: 3334076.01-AOC

DEKRA Testing Services (Zhejiang) Co., Ltd

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing Services (Zhejiang) Co., Ltd
No. 5. Changjiang Road, Great Bridge Industrial Park, North Baixiang, Wenzhou, 325603 Zhejiang, China
T +86 57762 868000 www.dekra-product-safety.com