

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50565532

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
G.J.Q.

Unser Zeichen *Our Reference*  
01-Dingjia-CN22UQXU 001

Ausstellungsdatum  
12.12.2022

*Date of Issue*  
(day/mo/yr)

## Genehmigungsinhaber *License Holder*

DELIXI ELECTRIC LTD  
Delixi High Tech Industrial Park,  
Liushi Town, Yueqing City,  
325604 Zhejiang  
P.R. China

## Fertigungsstätte *Manufacturing Plant*

Refer to latest revision  
of the annex list of factories

## Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*  
EN 60898-1:2019

Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)*

Lizenzentgelte - Einheit  
*License Fee - Unit*

Circuit Breaker (Miniature Circuit-breaker)

Type Designation : CDBA  
Number of Poles : 1P/2P/3P/4P  
Rated Operation Voltage (Ue) : 230/240VAC (1P/2P);  
400/415VAC (3P/4P);  
Rated Frequency : 50/60Hz  
Rated Current (In) : 6/10/16/20/25/32/40/50/63A  
Instantaneous Tripping Current : C/D-Type  
Rated Short-circuit Capacity  
(Icn) : 6kA  
Rated Service Short-circuit  
Capacity (Ics) : 6kA  
Rated Insulation Voltage (Ui) : 690V  
Impulse Withstand Voltage (Uimp) : 6,0kV  
Degree of Protection : IP20  
Suitability of Isolation : Yes  
Pollution Degree : 2

8

8

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

<http://www.tuv.com/safety> E-mail: [markcheck@tuv.com](mailto:markcheck@tuv.com)  
Fax: +49 221 806-3935

Zertifizierungsstelle

Wencai Zhang

**Anlage Fertigungsstättenliste**  
**/Attachment List of Factories**



R 50565532 0001

1 DELIXI ELECTRIC (WUHU) LTD

Wuhu Machinery Industrial Park,  
Wuhu city  
241100 Anhui  
P.R. China

2 DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park,  
Liushi Town, Yueqing City,  
325604 Zhejiang  
P.R. China

Dieser Anhang ersetzt den Vorgänger vom/  
This annex replaces the previous annex dated

Datum / Date 12.12.2022

Zertifizierungsstelle  
/ Certification Body

A blue ink signature of Wencai Zhang, written over a circular blue stamp that reads "TÜVRheinland Zertifizierungsstelle".

Wencai Zhang