



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE260303010023

Product

Moulded Case Circuit-Breakers

Applicant

DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City,
Zhejiang Province, 325604, P.R.China

Type/Model

CDBA-63B, CDBAZ-63B

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2025CQC0303-016977, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jan.28,2026

Valid until: Jan.27,2029

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE260303010023

CDBA-63B, CDBAZ-63B

Ui: 690V;

Uimp: 6kV;

Ue: AC230V/240V, DC48V/60V/80V;

In: 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

Over-current Release Type: Thermal Magnetic;

Selectivity Category: A;

Ics: 6kA;

Icu: 6kA;


Poles: AC: 1P+N (1protected poles with a switched neutral pole);

DC: 2P appearance;

AC: 50/60Hz;

Suitable for isolation.

DC Connection diagram:



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE