

IEC

IECEE

FB2-47-1

Ref. Certif. No.

CN57857

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit-breaker

Name and address of the applicant

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City,
Zhejiang Province, 325604, P.R.China

Name and address of the manufacturer

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City,
Zhejiang Province, 325604, P.R.China

Name and address of the factory

DELIXI ELECTRIC (WUHU) LTD
Wuhu Machinery Industrial Park, Wuhu City, Anhui Province,
241100, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui:690V;Uimp:
6kV;Ue:AC230V/240V,DC48V/60V/80V;In:6A,10A,16A,20A,
25A,32A,40A,50A,63A;Over-current Release Type: Thermal
Magnetic;Selectivity Category: A;Ics:6kA;Icu:6kA;Poles:
AC:1P+N(1 protected poles with a switched neutral
pole);DC: 2P appearance;AC:50/60Hz;Suitable for isolation

Trademark / Brand (if any)

DELIXI ELECTRIC

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

CDBA-63B,CDBAZ-63B

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th
Edition)As shown in the Test Report Ref. No. which
forms part of this Certificate

03601-A-22CB0035-S

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Sep.08,2022

Signature:

谢肇煦

Xie ZhaoXu



CB 0068612