



CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC22012354639

Valid from: Sep.03,2024

Valid until:long-term

NAME AND REGISTERED ADDRESS OF THE APPLICANT DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, 325604, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, 325604, P.R.China

NAME AND LOCATION OF THE FACTORY DELIXI ELECTRIC (WUHU) LTD
Wuhu Machinery Industrial Park, Wuhu City, Anhui Province, 241100, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION Circuit Breaker for IOT
CDBA-63B,CDBAZ-63B;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS CQC1148-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-382301-2020.

Date of original issued: Aug.09,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666
<http://www.cqc.com.cn>



CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO. : CQC22012354639

page1 of 1

paper:

This certificate and attachments shall be used at the same time, and the verification instructions can be found in the main certificate.

CDBA-63B,CDBAZ-63B

Ui:690V;Uimp: 6kV;

Ue:AC230V/240V,DC48V/60V/80V;

In:6A,10A,16A,20A,25A,32A,40A,50A,63A;

Over current release type :Thermal-magnetic type;

Selectivity Category:A;

Ics:6kA;Icu:6kA;

Poles: AC:1P+N(one protected pole,switched N pole);

DC:2P size(with one protected pole);


50/60Hz;

Suitable for isolation;

Control mode: Manual control mode,Remote automatic control mode;

Communication protocol (RS485)

DC connection mode:



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE