



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010304631642

**NAME AND ADDRESS OF THE APPLICANT**

DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, 325604, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, 325604, P.R.China

**NAME AND LOCATION OF THE FACTORY**

DELIXI ELECTRIC (WUHU) LTD

Wuhu Machinery Industrial Park, Wuhu City, Anhui Province, 241100, P.R.China

**PRODUCT NAME,MODEL AND SPECIFICATION**

AC Contactor

CJX2s-09(N),CJX2s-12(N),CJX2s-16(N),CJX2s-18(N),CJX2s-22(N),

CJX2s-09(N)11A,CJX2s-12(N)11A,CJX2s-18(N)11A,CJX2v-09(N),

CJX2v-12(N),CJX2v-18(N),CJX2H-09(N),CJX2H-12(N),CJX2H-18(N), CJX2H-09(N)Z,CJX2H-12(N)Z,CJX2H-18(N)Z

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.4-2020

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Mar.21,2025

**Valid until:** May.20,2029

Date of original issued: May.21,2024

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



**SIGNATURE:**

谢肇煦



**中国质量认证中心**  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

CERTIFICATE NO. : 2024010304631642

Appendix: Page 1 of 3

CJX2s-09(N),CJX2s-12(N),CJX2s-16(N),CJX2s-18(N),CJX2s-22(N),  
CJX2s-09(N)11A,CJX2s-12(N)11A,CJX2s-18(N)11A,CJX2v-09(N),  
CJX2v-12(N),CJX2v-18(N),CJX2H-09(N),CJX2H-12(N),CJX2H-18(N),  
CJX2H-09(N)Z,CJX2H-12(N)Z,CJX2H-18(N)Z  
Ui:690V;  
Uimp:6kV;  
Utilization category:AC-3,AC-4;  
CJX2s-09(N),CJX2s-09(N)11A,CJX2v-09(N),CJX2H-09(N),CJX2H-09(N)Z:  
Ith:25A;  
AC-3:Ue/Ie:AC220V/230V/9A,AC380V/400V/9A, AC660V/690V/6.6A;  
AC-4:Ue/Ie: AC220V/230V/3.5A,AC380V/400V/3.5A, AC660V/690V/1.5A;  
CJX2s-12(N),CJX2s-12(N)11A,CJX2v-12(N), CJX2H-12(N),CJX2H-12(N)Z:  
Ith:25A;  
AC-3:Ue/Ie:AC220V/230V/12A,AC380V/400V/12A, AC660V/690V/8.9A;  
AC-4:Ue/Ie: AC220V/230V/5A,AC380V/400V/5A, AC660V/690V/2A;  
CJX2s-16(N):  
Ith:25A;  
AC-3:Ue/Ie:AC220V/230V/16A,AC380V/400V/16A, AC660V/690V/8.9A;  
AC-4:Ue/Ie: AC220V/230V/5A,AC380V/400V/5A, AC660V/690V/2A;  
CJX2s-18(N),CJX2s-18(N)11A,CJX2v-18(N),CJX2H-18(N),CJX2H-18 (N)Z:  
Ith:32A;  
AC-3:Ue/Ie:AC220V/230V/18A,AC380V/400V/18A, AC660V/690V/12A;  
AC-4:Ue/Ie: AC220V/230V/7.7A,AC380V/400V/7.7A, AC660V/690V/3.8A;  
CJX2s-22(N):  
Ith:32A;  
AC-3:Ue/Ie:AC220V/230V/22A,AC380V/400V/22A, AC660V/690V/14A;  
AC-4:Ue/Ie: AC220V/230V/7.7A,AC380V/400V/7.7A, AC660V/690V/3.8A;  
Us:AC24V,36V,48V,110V,127V,220/230V,240V,380/400V,415V,440V,  
50Hz,50/60Hz;  
DC 24V~48V,110V~250V (Only for CJX2H-Z);  
Poles:3P;

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304631642

Appendix: Page 2 of 3

IP20(Terminals excluded);  
Auxiliary contacts: (embedded)  
1NO,1NC,1NO1NC;  
Ith:10A;  
AC-15:Ue/Ie:AC220V/1.6A,AC380V/0.95A;  
DC-13:Ue/Ie:DC220V/0.15A

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation



This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.




# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION


CERTIFICATE NO. : 2024010304631642

Appendix: Page 3 of 3

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation



直流控制型号  
常闭辅助触头组  
常开辅助触头组  
常规: 省略不写 N:可逆式交流接触器  
AC-3 使用类别下 380V/400V 时的额定工作电流值  
设计序号  
交流接触器



设计序号  
常闭辅助触头组  
常开辅助触头组  
常规: 省略不写 N:可逆式交流接触器  
AC-3 使用类别下 380V/400V 时的额定工作电流值  
设计序号  
交流接触器

注: 常开、常闭辅助触头对数及组合型号: 01、10、11

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.