

IEC

IECEE

EU-20

Ref. Certif. No.

CN57620

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC Contactor

Name and address of the applicant

DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, 325604, P.R.China

Name and address of the manufacturer

DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, 325604, P.R.China

Name and address of the factory

DELIXI ELECTRIC (WUHU) LTD

Wuhu Machinery Industrial Park, Wuhu City, Anhui Province, 241100, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

DELIXI ELECTRIC

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

CJX2s-265, CJX2s-330, CJX2s-400;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

(2022)FQIIDQ-0881

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Aug.15,2022

Signature:

谢肇煦

Xie ZhaoXu



CB 0069500

CJX2s-265, CJX2s-330, CJX2s-400;
Ui:1000V;
Uimp:8kV;
Utilization category: AC-1, AC-3, AC-4;
Us: AC50/60Hz /DC: 110V, 127V, 220V, 380V;
3P;
Auxiliary contact FC4-11(CQC2019010304179271):Ith:10A;AC-15:
230V/3.13A, 380V/1.89A, 690V/1.04A; DC-13:125V/0.55A, 220V/0.31A;
CJX2s-265:Ith:315A;
AC-1: Ue/Ie:220V/230V, 380V/400V, 660V/690V, 1000V/315A;
AC-3: Ue/Ie:220V/230V/265A, 380V/400V/265A, 660V/690V/170A;
AC-4: Ue/Ie:220V/230V/117A, 380V/400V/117A, 660V/690V/105A;
CJX2s-330:Ith:380A;
AC-1: Ue/Ie:220V/230V, 380V/400V, 660V/690V, 1000V /380A;
AC-3: Ue/Ie:220V/230V/330A, 380V/400V/330A, 660V/690V/225A;
AC-4: Ue/Ie:220V/230V/125A, 380V/400V/125A, 660V/690V/115A;
CJX2s-400:Ith:450A;
AC-1: Ue/Ie:220V/230V, 380V/400V, 660V/690V, 1000V/450A;
AC-3: Ue/Ie:220V/230V/400A, 380V/400V/400A, 660V/690V/303A;
AC-4: Ue/Ie:220V/230V/150A, 380V/400V/150A, 660V/690V/135A.

Page 1 of 1

Additional information (if necessary)

Date: Aug.15,2022

Signature:

谢肇煦

Xie ZhaoXu